

| Ц | BOILER CONNECTIONS |                   |              |   | BOILER RATINGS   |  |  |
|---|--------------------|-------------------|--------------|---|--|--|--|
|   | Α                  | STEAM OUTLET:     | 12" 300# FLG | 1 | NOMINAL BOILER HORSEPOWER 1700 HP  DESIGN PRESSURE 150 PSIG STEAM  GROSS OUTPUT 56908 MBH  STEAM OUTPUT (FROM & 212 °F) 58649 LBS/HR |  |  |
|   | В                  | LWCO:             | 1" NPT       | 4 |  |  |  |
| 2 | С                  | BOILER BLOWDOWN:  | 2" NPT       | 2 |  |  |  |
|   | D                  | SURFACE BLOWDOWN: | 1" NPT       | 2 |  |  |  |
|   | E                  | SAFTY VALVE:      | 2" NPT       | 1 | RATED INPUT 71134 MBH  |  |  |
|   | F                  | SAFTY VALVE:      | 2" NPT       | 1 | BOILER DATA  |  |  |
|   | G                  | MANWAY:           | 12" x 16"    | 1 |  |  |  |
|   | Н                  | HANDHOLE:         | 3" x 4"      | 5 | HEATING SURFACE (ASME) 8501 SqFt   |  |  |
| Н | J                  | CLEANOUT PORT:    | 18" ID       | 1 | FURNACE VOLUME 511.78 CuFt   |  |  |
|   | K                  | FEEDWATER:        | 3" NPT       | 2 | TURNAROUND VOLUME 125.12 CuFt  |  |  |
|   | L                  | AUXILIARY/VENT:   | 2" NPT       | 1 | STEAMING VOLUME284.52 CuFt   |  |  |
|   | М                  | LOW FIRE HOLD:    | 1" NPT       | 2 | STEAM RELEASE AREA 220.06 SqFt   |  |  |
|   | N                  | STACK TEMP:       | 1/2" NPT     | 2 | WATER CAPACITY:  |  |  |
| 1 | Р                  | SIGHT PORT:       | 1" PIPE      | 1 | (FULL12067 Gal @100365 Lbs   |  |  |
|   | Q                  | CHEMICAL FEED:    | 1" NPT       | 1 | (NWL)9938 Gal _ @82663 Lbs   |  |  |
|   | R                  | EXTRA CONNECTION: | 1 1/2" NPT   | 1 | SHIPPING WEIGHT: 111,800 Lbs   |  |  |
|   | S                  |                   |              |   |  |  |  |

| 5   |    |      |       |      |             |
|-----|----|------|-------|------|-------------|
| 4   |    |      |       |      |             |
| 3   |    |      |       |      |             |
| 2   |    |      |       |      |             |
| 1   |    |      |       |      |             |
| REV | BY | DATE | CHK'D | DATE | DESCRIPTION |

## NOTES

 VICTORY ENERGY, L.L.C. RESERVES THE RIGHT TO CHANGE DIMENSION DUE TO PRODUCT REVISION OR JOB REQUIREMENTS.

- 2. PRELIMINARY DIMENSIONS AND MAY BE USED FOR LAYOUT ONLY
- 3. CONTROLS & PIPING ARE MOUNTED PER SPECIFICATION SHEET
- 4. BOILER DESIGN CODE ASME SECTION \_\_\_I
- 5. DIMENSIONS ARE ± 1/2" UNLESS OTHERWISE NOTED
  6. BOILER INSULATED WITH 2" 8# DENSITY MINERAL FIBER
- 7. HORSEPOWER & RELATED INFO BASED ON 5 SqFt FIRING

INSULATION WITH 22 GAUGE STEEL JACKET

## NOTES

THIS DESIGN OR DRAWING IS NOT SOLD AND IS SUBJECT TO RECALL. REPRODUCTION OR COPYING RIGHTS ARE RESERVED SOLELY TO VICTORY ENERGY OPERATIONS, L.L.C. THE DRAWING HAS BEEN DELIVERED AND RECEIVED ON THE EXPRESSED CONDITIONS THAT IT IS NOT USED IN ANY WAY AGAINST THE INTERESTS AND BENEFITS OF VICTORY ENERGY OPERATIONS, L.L.C., AND THAT THIS DRAWING AND ALL COPIES OF IT WILL BE RETURNED TO VICTORY ENERGY OPERATIONS, L.L.C. IMMEDIATELY UPON DEMAND, AND THAT ALL INFORMATION DISCLOSED BY THIS DRAWING TO THE HOLDER SHALL BE HELD IN CONFIDENCE.

## VICTORY ENERGY

10701 E. 126th St. North, Collinsville, OK 74021 PHONE: 918-274-0023 FAX: 918-274-0059



| REPRESENTATIVE: |    |   |  |
|-----------------|----|---|--|
|                 | XX |   |  |
|                 |    | - |  |
| PROJECT:        |    |   |  |
|                 | XX |   |  |
|                 |    | • |  |

| SCALE | DRAWN BY | DATE | CHECKED BY | DATE | DRAWING NUMBER | BOILER MODEL   |
|-------|----------|------|------------|------|----------------|----------------|
| 1/75  | X        | Х    | X          | Х    | VE – XXXX      | F3-1700-S150-M |